



State of Ohio Environmental Protection Agency

**Northeast District Office**

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 467-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

February 13, 2007

RE: NOTICE OF VIOLATION  
FAILURE TO CONDUCT ANNUAL STAGE  
II COMPLIANCE TESTING  
DAPC FACILITY ID #024311124

**CERTIFIED MAIL**

Owner or Operator  
Convenient Food Mart  
426 Bacon Rd.  
Painesville, OH 44077

Dear Owner or Operator:

Our records indicate that Convenient Food Mart, located at 426 Bacon Rd. in Painesville, Ohio, did not conduct the required annual Stage II compliance testing in calendar year 2006. Stage II testing has not been conducted for several years.

Ohio Administrative Code (OAC) Rule 3745-21-09 (DDD) requires testing of the Stage II vapor control equipment annually for static leak and air to liquid ratio, as well as every five years for dynamic pressure. A copy of the rule is attached. We have also attached a listing of testing companies that routinely conduct Stage II tests in Ohio. Please contact one of them to arrange for testing before March 16, 2007.

We strongly advise that you conduct maintenance on your Stage II vapor control equipment prior to having the testing conducted. Also, be sure to have all of the records required by paragraph 3 of the above-mentioned rule available for inspection during the test.

If you have any questions, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB:bo

enclosures