



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

February 28, 2007

RE: NOTICE OF VIOLATION
FAILED ANNUAL STAGE II
COMPLIANCE TEST
NORTH RIDGEVILLE MARATHON
DAPC FACILITY ID 0247090720

CERTIFIED MAIL

Walid Abdelhalimid
North Ridgeville Marathon
35600 Center Ridge Rd.
North Ridgeville, OH 44039

Dear Mr. Abdelhalimid:

The annual Stage II compliance demonstration conducted at North Ridgeville Marathon located at 35600 Center Ridge Rd. in North Ridgeville, Ohio on February 23, 2007, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed
Pressure Decay Test	Not required this year
Dynamic Pressure Test	Passed
Ohio EPA Inspection	Passed

The A/L test for dispensers 1 and 6 failed due to having no vacuum. Also, our inspector noted that the hoses for dispensers 4, 5, and 6 need to be replaced and that fill cap on the premium tank needed to be replaced. The stations records need to be better organized.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Please schedule repairs and conduct a retest within 30 days of your receipt of this letter.

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution.

MR. WALID ABDELHALMID
FEBRUARY 28, 2007
PAGE 2

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,



Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

cc: Tom Kalman, Ohio EPA, DAPC, CO
Lisa Holscher, U.S. EPA, Region 5
Bob Princic, Ohio EPA, DAPC, NEDO