



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 1, 2007

RE: NOTICE OF VIOLATION
FAILED ANNUAL STAGE II
COMPLIANCE TEST
TRUE NORTH ENERGY LOCATION #25
DAPC FACILITY ID 0247040584

CERTIFIED MAIL

David Nye
True North Energy
3710 LeHarps Rd.
Youngstown, Ohio 44515

Dear Mr. Nye:

The annual Stage II compliance demonstration conducted at True North Energy Location #325 located at 905 Lorain Blvd. in Elyria, Ohio 44035 on February 7, 2007, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed
Pressure Decay Test	Passed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Passed

Dispensers #3 failed the A/L test.

Failed test results constitute a violation of Ohio Administrative Code Rule 3745-21-09 (DDD).

Please schedule repairs and conduct a retest within 30 days of your receipt of this letter.

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

cc: Tom Kalman, Ohio EPA, DAPC, CO
Lisa Holscher, U.S. EPA, Region 5
Bob Princic, Ohio EPA, DAPC, NEDO
Station Manager, GDF Station