



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 22, 2007

RE: NOTICE OF VIOLATION
ANNUAL STAGE II COMPLIANCE TEST
BP #22270/01946
DAPC FACILITY ID 0247090788

CERTIFIED MAIL

Becky Stackhouse
BP Products North America, Inc.
P.O. Box 6038
Artesia, CA 90702

Dear Ms. Stackhouse:

The annual Stage II compliance demonstration conducted at BP #22270/01946 located at 35985 Center Ridge Rd. in North Ridgeville, Ohio 44039 on April 26 and May 4, 2007, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Passed
Static Leak Test	Passed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Passed

The regular spill bucket was found to be leaking.

Please schedule repairs and conduct a retest within 30 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

cc: Station Manager, GDF Station
Tom Kalman, DAPC, CO
Bob Princic, DAPC, NEDO
Lisa Holscher, USEPA, Region V