



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 5, 2007

RE: NOTICE OF VIOLATION
FAILURE TO CONDUCT ANNUAL STAGE
II COMPLIANCE TESTING
DAPC FACILITY ID #0243151087

CERTIFIED MAIL

Terry Adams
Rusty's Auto Care Shell
30490 Euclid Ave.
Wickliffe, Ohio 44092

Dear Mr. Adams:

Our records indicate that Rusty's Auto Care Shell located at 30490 Euclid Ave. in Wickliffe, Ohio did not conduct the required annual Stage II compliance testing in calendar year 2006.

Ohio Administrative Code (OAC) Rule 3745-21-09 (DDD) requires testing of the Stage II vapor control equipment annually for static leak and air to liquid ratio, as well as every five years for dynamic pressure. A copy of the rule is attached. We have also attached a listing of testing companies that routinely conduct Stage II tests in Ohio. Please contact one of them to arrange for testing before February 28, 2007.

We strongly advise that you conduct maintenance on your Stage II vapor control equipment prior to having the testing conducted. Also, be sure to have all of the records required by paragraph 3 of the above-mentioned rule available for inspection during the test.

If you have any questions, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

enclosures