



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 9, 2008

RE: NOTICE OF VIOLATION
FAILED ANNUAL STAGE II COMPLIANCE TEST
TRUE NORTH ENERGY #325
OHIO EPA ID #0247040584

CERTIFIED MAIL

David P. Nye
True North Energy
3710 LeHarps Rd.
Youngstown, OH 44515

Dear Mr. Nye:

The annual Stage II compliance test conducted at True North Energy #325 located at 905 Lorain Blvd. in Elyria, Ohio 44035 on March 6, 2008 and March 19, 2008, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed on 3/6, passed on 3/19
Static Leak Test	Failed both dates
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Failed

During the 3/19 test, our inspector found that the tank vapor lines were either not properly manifolded or were blocked.

Further, the test report for the 3/6 test submitted by U.S. Tank Alliance indicates that all of the nozzles are 12 VW's while the 3/19 test report shows there is a mixture with other makes of nozzles. Please explain this discrepancy. Also, the test report for the 3/6 test indicates that the Static Leak test passed, while our inspector indicated that it failed. The 3/19 test also indicated that it failed. Please explain this discrepancy as well.

Proper maintenance and repair are essential to maintaining compliance and minimizing emissions to the atmosphere.

Please schedule repairs and conduct a retest within 14 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

DAVID P. NYE
APRIL 9, 2008
PAGE 2

Violations of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution.

Sincerely,

A handwritten signature in cursive script that reads "Dennis Bush".

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

cc: Bob Prinic, DAPC, NEDO
Tom Kalman, DAPC, CO
Lisa Holscher, USEPA, Region V
Station Manager
Kathy Pasternak, US Tank Alliance