



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 20, 2008

RE: NOTICE OF VIOLATION
FAILED ANNUAL STAGE II COMPLIANCE TEST
CIRCLE K #5320
OHIO EPA ID #0247020966

CERTIFIED MAIL

Kevin Merritt
Circle K Corp.
315 Commons Mall
Columbus, IN 47201

Dear Mr. Merritt:

The annual Stage II compliance test conducted at Circle K #5320 located at 36071 Chester Rd. in Avon, Ohio 44011 on February 25 and March 24, 2008, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed on dispensers 15 & 16
Static Leak Test	Passed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Passed

Please schedule repairs and conduct a retest within 14 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution. An enforcement action will be initiated if this site does not return to compliance within 14 days of your receipt of this letter.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

cc: Bob Princic, DAPC, NEDO
Tom Kalman, DAPC, CO
Lisa Holscher, USEPA, Region V
Station Manager