



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 6, 2008

RE: NOTICE OF VIOLATION
FAILED ANNUAL STAGE II COMPLIANCE TEST
CHARDON MARATHON
OHIO EPA ID #0228000248

CERTIFIED MAIL

Ray Sines
Sines & Sons
2481 North Ridge Rd.
Painesville, Ohio 44077

Dear Mr. Sines:

The annual Stage II compliance test conducted at Chardon Marathon located at 380 Center St. in Chardon, Ohio 44024 on August 5, 2008, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Passed
Static Leak Test	Failed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Failed

The static leak test failed due to a leaking drop tube on the regular gasoline storage tank.

Our inspector noted that the maintenance and gasoline delivery records were not kept on site. Also, the Stage II training certificate was not readily available. OAC Rule 3745-21-09 (DDD) requires that these be kept on site and available for our review.

Please schedule repairs and conduct a retest within 14 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution. An enforcement action will be initiated if this site does not return to compliance within 14 days of your receipt of this letter.

Sincerely,

Dennis Bush
Environmental Manager
Division of Air Pollution Control

DB:bo

cc: Bob Princic, DAPC, NEDO
Tom Kalman, DAPC, CO
Lisa Holscher, USEPA, Region V
Station Manager