



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 11, 2008

RE: NOTICE OF VIOLATION  
FAILED 5-YEAR STAGE II COMPLIANCE TEST  
GARFIELD & MISSOURI MARATHON  
OHIO EPA ID #0247080697

CERTIFIED MAIL

Brian Logue  
Garfield & Missouri Marathon  
300 Central Viaduct  
Cleveland, OH 44225

Dear Mr. Logue:

The 5-year Stage II compliance test conducted at Garfield & Missouri Marathon located at 2312 Garfield Blvd. in Lorain, Ohio 44052 on December 13, 2007, failed to demonstrate compliance for the following parameters:

| <u>Parameter</u>      | <u>Pass/Fail</u> |
|-----------------------|------------------|
| A/L Test              | Failed           |
| Static Leak Test      | Passed           |
| Dynamic Pressure Test | Passed           |
| Ohio EPA Inspection   | Passed           |

The A/L test failed on all four dispensers

Please schedule repairs and conduct a retest within 30 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

I have enclosed a Permit-by-Rule Notification form. Please complete the form and return it as per the instructions. This will replace any needed Permit-to-Operate or Permit-to-Install and will mean you no longer have to pay the biannual emission fees.

Violation of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB:bo

cc: Bob Princic, DAPC, NEDO  
Tom Kaiman, DAPC, CO  
Lisa Holscher, USEPA, Region V  
Station Manager