



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

March 26, 2008

RE: NOTICE OF VIOLATION  
FAILED 5-YEAR STAGE II COMPLIANCE TEST  
UNI-MART #74775  
OHIO EPA ID #0243111053

Patti Turiano  
Uni-Mart, Inc.  
477 E. Beaver Ave.  
State College, PA 16801

CERTIFIED MAIL

Dear Ms. Turiano:

The 5-year Stage II compliance test conducted at Uni-Mart #74775 located at 6000 Vrooman Rd. in Painesville, Ohio 44077 on October 23, 2007, January 23, 2008 and March 25, 2008, failed to demonstrate compliance for the following parameters:

<u>Parameter</u>	<u>Pass/Fail</u>
A/L Test	Failed on dispensers 3 and 8
Static Leak Test	Passed
Dynamic Pressure Test	Not required this year
Ohio EPA Inspection	Passed

During the first test on October 23, 2007, the Static Leak and Dynamic Pressure tests passed, but the A/L test failed for dispensers 1, 3, 4, 7, and 8. After the retest on January 23, 2008, only dispensers 3 and 8 failed. There have been apparently no repairs made because the same two dispensers failed the March 25, 2008, retest.

Please schedule repairs and conduct a retest within 14 days of your receipt of this letter.

Failed test results constitute a violation of OAC Rule 3745-21-09 (DDD).

Violations of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution. An enforcement action will be initiated if this site does not return to compliance within 14 days of your receipt of this letter.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB:bo

cc: Bob Princic, DAPC, NEDO  
Tom Kalman, DAPC, CO  
Lisa Holscher, USEPA, Region V  
Station Manager