



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 5, 2007

RE: NOTICE OF VIOLATION  
THORNE'S MARKET  
OHIO EPA ID #0204000493

Mr. Bill Thorne  
Bias Realty, Ltd.  
P.O. Box 619  
Salem, OH 44460

Dear Mr. Thorne:

Ohio EPA has received and approved the Permit by Rule Notification that you submitted for Thorne's Market in Jefferson, Ohio.

We have no record of a gasoline station at the address listed (344 S. Chestnut St.). Rule 3745-21-09 (DDD) of the Ohio Administrative Code requires that all gasoline dispensing facilities that have Stage II vapor controls conduct annual tests to document that the equipment is working properly. Thorne's Market has never conducted such testing.

I have attached a copy of the Rule and a list of companies that perform such testing. Please contact one of them and arrange to have the testing conducted by the end of August 2007.

Violations of state air pollution control regulations are punishable by a civil penalty of \$25,000 per violation. Issuance of this notice does not excuse any violation of state law regarding air pollution.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1223.

Sincerely,

Dennis Bush  
Environmental Manager  
Division of Air Pollution Control

DB/mt

enclosure: Rule 3745-21-07  
List of testing companies