



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7009 3410 0002 1934 1066
RETURN RECEIPT REQUESTED**

November 5, 2010

Philip Santora
Cleveland Clinic – Children’s Hospital for Rehabilitation
2801 MLK Jr. Drive
Cleveland, Ohio 44104

**FACILITY ID: 13-18-00-0252
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. Santora:

On October 8, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requiring Cleveland Clinic – Children’s Hospital for Rehabilitation (Children’s Hospital) to submit permit-by-rule (PBR) notification forms, per OAC 3745-31-03(A)(4)(b), for the operation of emergency electrical generators. CDAQ received, on October 25, 2010, appropriate PBR notification forms for three emergency generators at Children’s Hospital.

The corrective action was received in a timely manner and appropriate steps were taken to bring each source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA’s concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Valerie Shaffer at (216) 664-6292. All correspondence with CDAQ must include the Ohio EPA facility identification number for Children’s Hospital: 13-18-00-0252.

Sincerely,

Linda Kimmy for G.B.

George Baker
Chief of Enforcement, CDAQ

GB/vls

cc:

John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318000252\2010-10-05 NEAR.docx