



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 70022030000118077743
RETURN RECEIPT REQUESTED**

November 8, 2010

Ms. Karen L. Dethloff
Director, Facilities Management
MetroHealth Medical Center
2500 MetroHealth Drive
Cleveland, Ohio 44109-1998

**FACILITY ID: 13-18-00-2965
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Ms. Dethloff:


On September 15, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requiring MetroHealth Medical Center (MetroHealth) to submit a compliance plan that includes a timeline for completing stack testing Emission Unit (EU) B004: Babcock & Wilcox 91 mmBtu/hr Natural Gas / No. 2 Fuel Oil Boiler and for annual burner tune ups for EUs B006 – B010: Vapor Power 23.647 mmBtu/hr Natural Gas / No. 2 Fuel Oil. In addition, CDAQ requested MetroHealth provide a listing of any other NOx emitting units and note whether or not each unit is subject to NOx-RACT requirements.

CDAQ is in receipt of a corrective action plan dated October 15, 2010, that includes a timeline for stack testing EU B004 and a statement that MetroHealth's eleven emergency generators are exempt from NOx-RACT requirements. Additionally, CDAQ has received via e-mail on November 8, 2010, a timeline for annual burner tune ups for EUs B006 – B010.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Linda Kimmy at 216-664-2985. All correspondence with CDAQ must include the Ohio EPA facility identification number for MetroHealth: 13-18-00-2965.

Sincerely,


George Baker
Chief of Enforcement, CDAQ



GB/lk

cc:

Michael J. Krzywicki, CDAQ
John Paulian, Ohio EPA Central Office
Alan Harness, Ohio EPA, DAPC
Jim Orlemann, Ohio EPA, DAPC
William MacDowell, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318002965\2010-9-15 NOx-RACT NEAR.doc