



October 11, 2010

Linda Kimmy  
Cleveland Division of Air Quality  
75 Erieview Plaza 2<sup>nd</sup> Floor  
Cleveland, OH 44114-1839

Alan Harness  
Ohio EPA, DAPC  
Lazarus Government Center  
50 West Town Street, Ste 700  
PO Box 1049  
Columbus, OH 43216-1049

RE: Written notification of compliance with 3745-110-03 (A)

Facility Information; MetroHealth Medical Center  
2500 MetroHealth Drive  
Cleveland, OH 44109  
Facility ID: 13-18-00-2965

This letter is to serve as written notification to the Director to certify that emissions units B006, B007, B008, B009, and B010 are in compliance with NO<sub>x</sub> RACT requirements of OAC 3745-110-03 (A) as required by OAC 3745-110-04 (A) (1).

Sincerely,

A handwritten signature in cursive script, appearing to read "Karen Dethloff".

Karen Dethloff  
Director Facilities Management

**Kimmy, Linda**

---

**From:** Karen Dethloff [kdethloff@metrohealth.org]  
**Sent:** Monday, November 08, 2010 8:36 AM  
**To:** Kimmy, Linda  
**Cc:** Bob Engles; John Kinzer; Tomislav Markovic  
**Subject:** Re: NOx-RACT NOV Response Clarification

Linda,  
To clarify our October 15, 2010 response to the September 15, 2010 NOV, the MetroHealth Medical Center plans to schedule all future tune ups of its small boilers in the fourth quarter of each year. Please let me know if you need any further information.  
Karen

Karen L. Dethloff, BS, MS, MBA, FASHE, CHFM Director Facilities Management MetroHealth Medical Center 2500 MetroHealth Drive Cleveland, Ohio 44109-1998

Phone: 216-778-5544  
Fax: 216-778-3303

>>> "Kimmy, Linda" <LKimmy@city.cleveland.oh.us> 11/2/2010 8:56 AM >>>  
Ms. Dethloff,

I am requesting a clarification on MetroHealth's response dated October 15, 2010, to the September 15, 2010, Notice of Violation (NOV) that the Cleveland Division of Air Quality issued for "failure to certify compliance as required by Ohio Administrative Code (OAC) Rule 3745-110-04."

The NOV requested a timeline for annual burner tune ups for the small boilers, Emission Units B006 - B010. MetroHealth's response included a written compliance certification stating the small boilers have all undergone documented annual tune ups. We are looking for a definitive timeline as to when you will be conducting annual burner tune ups in the future. An example - burner tune ups will be conducted every year in August or burner tune ups will be conducted every summer when we do maintenance or...

These are just a few examples of what we are looking for; please provide a clarification to the requested timeline as to when burner tune ups will be conducted in the future at MetroHealth Medical Center (13-18-00-2965).

Thank you, Linda

Linda J. Kimmy  
Field Enforcement Manager  
Cleveland Department of Public Health  
Division of Air Quality  
75 Erieview Plaza - Floor 2  
Cleveland, Ohio 44114-1839

(office) 216-664-2985 (fax) 216-420-8047  
lkimmy@city.cleveland.oh.us <mailto:lkimmy@city.cleveland.oh.us>  
www.clevelandhealth.org <http://www.clevelandhealth.org/>

MetroHealth is an Academic Health Care System committed to Our Communities by Saving Lives, Restoring Health, Promoting Wellness, and providing Outstanding, Life-long Care Accessible to All. Visit us at <http://www.metrohealth.org> or for stories of MetroHealth miracles and hope, visit: <http://www.mhwallofhope.com>

This email and all attachments that may have been included are intended only for the use of the party to whom/which the email is addressed and may contain information that is privileged, confidential, or exempt from disclosure under applicable law. If you are not the addressee or the employee or agent of the intended recipient, you are hereby notified that you are strictly prohibited from printing, storing, disseminating, distributing, or copying this communication. If you have received this notification in error, please contact the Director of Risk/Privacy Management at (216)778-5728. For a copy of our Notice of Privacy Practices, please visit:<http://www.metrohealth.org/general/privacy.asp>