



**Environmental
Protection Agency**

John E. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott A. Holte, **Director**

July 12, 2012

RE: **CERTIFIED WARNING LETTER**
FAILURE TO COMPLETE REQUIRED
STAGE II TESTING
GAS USA
DAPC FACILITY ID: 0247080802

CERTIFIED MAIL

Rachid Bounit
Gas USA
4935 West Erie St
Lorain, OH 44053

Dear Mr. Bounit:

This letter inform you that Gas USA, located at 4935 West Erie Street, Lorain, Ohio, has violated the Stage II testing requirements found in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD).

A representative from this office witnessed Stage II testing conducted at this station on June 7, 2012. The station passed the static leak portion of the testing, but failed the air-to-liquid ratio testing for all eight dispensers. As of the date of this letter, no retest has been scheduled.

Please schedule a retest as soon as possible, but **no later than within seven days of receipt of this letter**. In other words, testing should occur as soon as the testing firm and our office can work out a date, but the act of scheduling the testing should be done within seven days.

Failure to comply with the above request may result in an enforcement action up to and including referral to the Central Office of Ohio EPA for appropriate action.

The submission of the requested information does not constitute a waiver of Ohio EPA's authority to seek civil penalties as provided in ORC 3704.06. Ohio EPA will decide whether to pursue or decline to pursue penalties regarding this matter at a later date.

If you have any questions regarding this letter, please do not hesitate to contact me at (330) 963-1270.

Sincerely,

Tim Fischer
Environmental Supervisor
Division of Air Pollution Control

TF:bo