



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL #70022030000118089142
RETURN RECEIPT REQUESTED

April 6, 2009

David Sabol
Chief, Engineering Service
V.A. Medical Center
10701 East Boulevard
Cleveland, OH
44106

HPF
NON-HPV
FACILITY ID: 13-18-00-4330
RECEIPT OF CORRECTIVE ACTION PLAN: NOTICE OF VIOLATION

Dear Mr. David Sabol:

On March 5, 2009, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requesting that V.A. Medical Center submit a corrective action plan regarding the following violations: failing to pay city permit fees, operating emission units without proper permits and failing to comply with terms and conditions of issued permits. CDAQ is in receipt of a corrective action plan dated March 30, 2009, stating that you will comply with payment of 2006, 2007 and 2008 city permit fees, submit permit by rule notifications for each generator and documentation stating use of proper testing methods, which comply with permit terms and conditions, for all future fuel deliveries by April 20, 2009. Failure to do so may result in referral to Ohio EPA or U.S. EPA for further enforcement action. Fulfillment of your commitments included in the corrective action plan and/or any modifications contained within this letter does not constitute a waiver of CDAQ's ability to refer this matter to Ohio EPA or U.S. EPA for further enforcement action.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Andrew Kenney at 216-420-7683. All correspondence with CDAQ must include the Ohio EPA facility identification number for V.A. Medical Center: 13-18-00-4330.

Sincerely,

A handwritten signature in cursive script that reads "Valencia White".

Valencia White
Field Enforcement Manager, CDAQ



VW/ak

cc: John Paulian, Ohio EPA Central Office
Lisa Holscher, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318004330\2009-4-3 RCAP.doc