



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Fricvow Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7009 3410 0002 1933 8271
RETURN RECEIPT REQUESTED

April 15, 2010

Danny Coffey
Speedway #9230
500 Speedway Dr.
Enon, OH 45503

FACILITY ID: 13-18-00-6050
NOTICE OF VIOLATION FOLLOW-UP LETTER

Dear Mr. Coffey:

On March 30, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requiring Speedway #9230 to make the necessary repairs, conduct a re-test of the Static Leak (SL) test and submit the test results within thirty (30) days. CDAQ is in receipt of a corrective action plan dated April 7, 2010, where CDAQ witnessed a re-test of the SL test and Speedway #9230 passed. CDAQ is also in receipt of test results submitted on April 14, 2010 for the SL re-test.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Speedway #9230: 13-18-00-6050.

Sincerely,
Linda Kivrony for G.B.
George Baker
Chief of Enforcement, CDAQ

GB/MM

cc: John Paulian, Ohio EPA Central Office
Lisa Holscher, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318006050\2010-3-29 NEAR.doc

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Danny Coffey
 Speedway #9250
 500 Speedway Dr.
 Eron, OH 43503

2. Article Number
(Transfer from service label)

7009 3410 0002 1933 8271

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X

W. W. B. B.

 Agent Address

B. Received by (Printed Name)

DUSTIN BARTON

C. Date of Delivery

4-21-10

D. Is delivery address different from item 1? YesIf YES, enter delivery address below: No

3. Service Type

 Certified Mail Express Mail Registered Return Receipt for Merchandise Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

 Yes



Speedway SuperAmerica LLC

April 14, 2010

P.O. Box 1500
Springfield, OH 45501
Telephone 937-864-3000

CERTIFIED MAIL

Megan Murphy
Cleveland Division of Air Quality
75 Erievue Plaza 2nd Floor
Cleveland, Ohio 44114-1839

ORIGINAL

Re: Notice of Violation: Failing Annual Stage II Testing

Dear Megan Murphy:

This letter is in response to the Notice of Violation we received on April 5, 2010 for Speedway Store #9230, located at 17600 Brook Park Road, in Brook Park, Ohio for the following issue:

1. **Failed a Static Leak (SL) test on March 29, 2010. Make necessary repairs conduct a retest, and submit test results within 30 days.** – Please see the attached Source Test Results Pressure Decay Test, dated April 7, 2010, for passing test results.

If you have any questions or require additional information feel free to contact me at (937) 863-7034. Thank you for your time and attention in this matter.

Sincerely,

Michelle L. McKee
Environmental Compliance Manager

Enclosures

