



City of Cleveland  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erieview Plaza, Suite 200  
Cleveland, Ohio 44114-1839  
216/664-2297 • Fax: 216/420-8047  
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL #70093410000219339605  
RETURN RECEIPT REQUESTED**

November 2, 2010

Sarkia Khoury  
7025 Fleet, Incorporated  
7025 Fleet Avenue  
Cleveland, OH 44105

**FACILITY ID: 13-18-00-6154  
RECEIPT OF CORRECTIVE ACTION PLAN: FAILING TO PERFORM  
REQUIRED STAGE II TESTING, FAILING TO MAINTAIN REQUIRED RECORD  
KEEPING, OPERATING AN EMISSION UNIT WITHOUT A PROPER PERMIT  
AND FAILURE TO COMPLETE TRAINING REQUIRED BY OHIO EPA**

Dear Mr. Khoury:

On September 14, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requesting that 7025 Fleet, Incorporated (Sunoco Incorporated) submit either a permit-to-install/operate (PTIO) application or a permit-by-rule (PBR) notification form. CDAQ also requested 7025 Fleet, Incorporated (Sunoco Incorporated) submit proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility. As well as a template of a log to maintain records of all repair and maintenance work performed (including, but not limited to, work performed to meet manufacturer's specifications or CARB certification requirements), or any other modifications made to the vapor control system within thirty (30) days of receipt of the Notice of Violation.

CDAQ received a PBR notification on October 28, 2010. You are still expected to comply with submitting:

- Proof of attendance and completion of the training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility.
- A template of a log to maintain records of all repair and maintenance work performed (including, but not limited to, work performed to meet manufacturer's specifications or CARB certification requirements), or any other modifications made to the vapor control system
- Scheduling and performing all required Stage II tests and submitting test results (The last date of passing Stage II tests on file with CDAQ is March 4,



2009)

within 10 days of receipt of this letter.

Failure to do so may result in referral to Ohio EPA or U.S. EPA for further enforcement action. Fulfillment of your commitments included in the corrective action plan and/or any modifications contained within this letter does not constitute a waiver of CDAQ's ability to refer this matter to Ohio EPA or U.S. EPA for further enforcement action. Please submit any future correspondence related to this matter to the following enforcement representative:

Andrew Kenney  
Cleveland Division of Air Quality  
75 Erieview Plaza 2<sup>nd</sup> Floor  
Cleveland, Ohio 44114-1839

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Andrew Kenney at 216-420-7683. All correspondence with CDAQ must include the Ohio EPA facility identification number for 7025 Fleet, Incorporated: 13-18-00-6154.

Sincerely,

*Lynda Kimmey for G.B.*  
George Baker  
Chief of Enforcement, CDAQ

GB/ak

cc: John Paulian, Ohio EPA Central Office  
William MacDowell, U.S. EPA Region V  
Facility File and L:\Data\Facilities\1318006154\2010-9-3 RCAP.doc