



19511 Progress Drive, Suite 3
Strongsville, OH 44149

7/20/2011

West Park Shell #2370
13960 Lorain Ave.
Cleveland, OH 44111
Attn: Manager

This is to advise/confirm that we are scheduled to perform your annual compliance testing services on the date and time listed below.

Test date:	7/28/2011
Approx test time:	9:00 AM
Type of test:	Stage II Vapor Recovery System, LD
Reason:	Annual Compliance

Please feel free to call me should you have any questions.

Thank you for your cooperation!

Kathy Pasternak
US Tank Alliance
440-236-7705



FUEL REQUIREMENTS: Stage I & II Vapor Recovery System Testing (SII)

Product is needed, deliveries must be made at least 3 hours prior to the scheduled test.
Gasoline tanks cannot exceed 75% of the total gasoline storage capacity on site
Maximum ullage (empty space) allowed is 25K

APPROXIMATE DOWN TIME:

Tank testing	4 hours	We will leave a product open whenever possible
Line testing	2 hours	We will leave a product open whenever possible
LD testing	1 hour	We will leave a product open whenever possible
Stage II vapor recovery	3 hours	All gasoline products will be out of service
Stage I vapor recovery	1-1/2 hours	All gasoline products will be out of service