



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7010 1870 0000 6591 3523
RETURN RECEIPT REQUESTED

December 2, 2011

Ali Allan
Hanini Marathon
3501 Lorain Avenue
Cleveland, Ohio 44113

FACILITY ID: 13-18-00-6918
NOTICE OF VIOLATION FOLLOW-UP LETTER

Dear Mr. Allan:

On September 16, 2011, and October 24, 2011, the Cleveland Division of Air Quality (CDAQ) issued Notices of Violation to Hanini Marathon for failure to successfully pass an Air-to-Liquid (A/L) ratio test on all gasoline grades on pump #5. Additionally, operating instructions for the vapor control system, specifically prohibiting the "topping off" of the motor vehicle fuel tank, were not conspicuously posted in each gasoline dispensing area.

CDAQ is in receipt of passing A/L ratio test results conducted on November 23, 2011. Additionally, appropriate operating instructions were posted in each dispensing area. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. If you have any questions, please call Valerie Shaffer at (216) 664-6292. All correspondence with CDAQ must include the Ohio EPA facility identification number for Hanini Marathon: 13-18-00-6918.

Sincerely,

A handwritten signature in black ink that reads "Linda Kimmy".

Linda Kimmy
Field Enforcement Manager

LK/vls

cc: John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318006918\2011-09-08 NEAR.docx