



City of Cleveland  
Frank G. Jackson, Mayor

Department of Public Health  
Division of Air Quality  
75 Erieview Plaza, Suite 200  
Cleveland, Ohio 44114-1839  
216/664-2297 • Fax: 216/420-8047  
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13  
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7009 3410 0002 1934 1769  
RETURN RECEIPT REQUESTED**

April 4, 2011

Timothy Ujvari  
Ohio Turnpike Commission  
682 Prospect St.  
Berea, OH 44017

NON-HPV

**FACILITY ID: 13-18-08-6044  
NOTICE OF VIOLATION/NOTICE OF VIOLATION FOLLOW-UP LETTER:  
Failing annual Stage II testing**

Dear Mr. Ujvari:

On March 22, 2011, the Cleveland Division of Air Quality (CDAQ) inspected Ohio Turnpike Commission (OTC Great Lakes) located at 2000 East Edgerton Road in Broadview Heights. This letter serves as notification that you were operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

OTC Great Lakes conducted annual Stage II testing on March 22, 2011. The Static Leak (SL) test failed at this time due to a hole in the drop tube and a crack in the spill bucket on one of the tanks. The Air-to-Liquid (A/L) Ratio test was also conducted and passed at this time. The failure to successfully pass the testing requirements in Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(2) while causing, allowing or permitting the transfer of gasoline from a stationary storage tank into a motor vehicle are violations of Ohio Revised Code (ORC) Section 3704.05(G) and OAC Rule 3745-21-09(DDD)(1)(b) and (c).

CDAQ witnessed Stage II testing on March 31, 2011 after repairs were made. OTC Great Lakes passed the SL test at this time.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.


1. Article Addressed to:

Timothy Ujvari  
OTC / Great Lakes  
682 Prospect St.  
Berua, OH 44017

2. Article Number  
(Transfer from service label)

7009 3410 0002 1934 1769

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature  Agent  
**X**   Addressee

B. Received by (Printed Name) C. Date of Delivery

D. Is delivery address different from item 1?  Yes  
If YES, enter delivery address below:  No

3. Service Type  
 Certified Mail  Express Mail  
 Registered  Return Receipt for Merchandise  
 Insured Mail  C.O.D.

4. Restricted Delivery? (Extra Fee)  Yes