



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7009 3410 0002 1934 1295
RETURN RECEIPT REQUESTED**

December 29, 2010

Brian Radway
Quick Fuel Fleet Services #2306
11815 West Bradley Road
Milwaukee, WI 53224

NON-HPV

FACILITY ID: 13-18-12-8273

NOTICE OF VIOLATION: Failure to conduct annual Stage II testing

Dear Mr. Radway:

On November 11, 2010, the Cleveland Division of Air Quality (CDAQ) inspected Quick Fuel Fleet Services #2306 located at 15340 Diana Drive in Brookpark, OH. This letter serves as notification that you are operating sources in violation of the following applicable air statutes, air regulations, or air permit conditions.

Quick Fuel Fleet Services #2306 has failed to conduct Stage II testing at the frequency specified in California Air Resources Board (CARB) executive order G-70-191-AA which states that the owner or operator shall conduct and pass a Static Leak test and an Air-to-Liquid Ratio test at least once in each twelve month period. This is a violation of Ohio Administrative Code (OAC) Rule 3745-21-09(DDD)(2). A Static Leak test was conducted and passed on November 11, 2010. An Air-to-Liquid Ratio test was not conducted at this time.

Unless you undertake some type of corrective action with respect to the above noted violations, you will remain in non-compliance. CDAQ requests that Quick Fuel Fleet Services #2306 conduct the Air-to-Liquid Ratio test and submit test results for both the Static Leak and Air-to-Liquid Ratio test within fourteen (14) days of receipt of this letter to the following enforcement representative:

Megan Murphy
Cleveland Division of Air Quality
75 Erieview Plaza 2nd Floor
Cleveland, Ohio 44114-1839

If there is insufficient time to correct the alleged violations within this timeframe, a written response which includes a timeline for correcting the alleged violations must be received within fourteen (14) days of receipt of this letter.

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Brian Radway
 Quick Fuels #2306
 11815 West Bradley Rd.
 Milwaukee, WI 53224


2. Article Number

(Transfer from service label)

7009 3410 0002 1934 1295

COMPLETE THIS SECTION ON DELIVERY

A. Signature


 Agent AddresseeB. Received by (*Printed Name*)

T. Wherman

C. Date of Delivery

1-3-11

D. Is delivery address different from item 1? YesIf YES, enter delivery address below: No

JAN 03 2011

3. Service Type

 Certified Mail Express Mail Registered Return Receipt for Merchandise Insured Mail C.O.D.4. Restricted Delivery? (*Extra Fee*) Yes