

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Russell LANG
 ATHN: LANG's Marathon
 5994 Mayfield Rd
 Mayfield Hts, OH 44124

2. Article Number
(Transfer from service label)

COMPLETE THIS SECTION ON DELIVERY

A. Signature
 (X) *June Block* Agent Addressee

B. Received by (*Printed Name*) C. Date of Delivery
JESSE BLOCK *10/1-2011*

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type

Certified Mail Express Mail
 Registered Return Receipt for Merchandise
 Insured Mail C.O.D.

4. Restricted Delivery? (*Extra Fee*) Yes

7003 1010 0004 2923 6943



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY

CERTIFIED MAIL 7003 1010 0004 2923 6943
RETURN RECEIPT REQUESTED

May 25, 2011

Russell Lang
Lang's Marathon
5994 Mayfield Road
Mayfield Heights, OH 44124

NON-HPV

FACILITY ID: 13-18-33-6075
NOTICE OF VIOLATION FOLLOW-UP LETTER

Dear Mr. Lang:

On May 10, 2011, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation to Lang's Marathon for failure to successfully pass a Static Leak test on May 4, 2011. The Static Leak test failed due to leaking vac motors on dispensers #1, #2, #7, and #8.

On May 25, 2011, the Static Leak was retested at your gasoline dispensing facility (GDF) and successfully passed. The Air-to-Liquid and Dynamic Pressure tests also passed at this time. The necessary repairs and tests were conducted timely and appropriate steps were taken to bring your GDF into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Valerie Shaffer at (216) 664-6292. All correspondence with CDAQ must include the Ohio EPA facility identification number for Lang's Marathon: 13-18-33-6075.

Sincerely,

A handwritten signature in cursive script that reads "Linda Kimmy".

Linda Kimmy
Field Enforcement Manager

LK/

cc:

John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318336075\2011-5-4 NEAR.docx

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Russell Lang
Lang's Marathon
5994 Mayfield Rd.
Mayfield Hts., OH 44124

2. Article Number

(Transfer from service label)

7009 3410 0002 1934 1950

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1640

COMPLETE THIS SECTION ON DELIVERY

A. Signature

- Agent
- Addressee

B. Received by (Printed Name)

C. Date of Delivery

5-3-11

D. Is delivery address different from item 1? Yes
If YES, enter delivery address below: No

3. Service Type

- Certified Mail Express Mail
- Registered Return Receipt for Merchandise
- Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes