

City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Suite 200
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7009 3410 0002 1934 0755
RETURN RECEIPT REQUESTED**

August 23, 2010

Ebrahim Najar
Pearl Road American Petroleum
1160 Gold Crest Dr.
Medina, OH 44256

**FACILITY ID: 13-18-55-6321
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. Najar:

On July 12, 2010, the Cleveland Division of Air Quality (CDAQ) issued a Notice of Violation requiring Pearl Road American Petroleum dba Gas N Food (Gas N Food) to complete the necessary repairs to dispenser #3/4 and conduct a re-test of the Air-to-Liquid Ratio test, then submit test results within thirty (30) days of receipt of the letter. CDAQ is in receipt of a corrective action plan dated August 20, 2010 at which time test results were received showing passing test results for dispenser #3/4.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action. Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for Gas N Food: 13-18-55-6321.

Sincerely,

George Baker for G.B.

George Baker

Chief of Enforcement, CDAQ

GB/mm

cc: John Paulian, Ohio EPA Central Office
Lisa Holscher, U.S. EPA Region V
Facility File and L:\Data\Facilities\1318556321\2010-7-12 NEAR.doc

SENDER: COMPLETE THIS SECTION

- Complete Items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Ebrahiam Najjar
 Pearl Road AP
 1160 Gold Crest Dr.
 Medina, OH 44256

2. Article Number
(Transfer from service label)

7009 3410 0002 1934 0755

COMPLETE THIS SECTION ON DELIVERY

A. Signature

 Ebrahiam Najjar

-
- Agent
-
-
- Addressee

B. Received by (Printed Name)

 Ebrahiam Najjar

C. Date of Delivery

 D. Is delivery address different from Item 1? Yes
 If YES, enter delivery address below: No

3. Service Type

-
- Certified Mail
-
- Express Mail
-
-
- Registered
-
- Return Receipt for Merchandise
-
-
- Insured Mail
-
- C.O.D.

4. Restricted Delivery? (Extra Fee) Yes


UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •
Cleveland Division of Air Quality
Attn: Megan Murphy
75 Erieview Plaza 2nd Flr.
Cleveland, OH 44114

13-18-55 6321 2010-7-12 NEAR



Environmental Compliance Technologies

A/L TEST SUMMARY OF TEST RESULTS

B 18 55 6321

RECEIVED

AUG 20 2010

GDF NAME AND ADDRESS
Location #8952
A&P
8952 PEARL RD.
STRONGSVILLE, OH 44136

TYPE OF DISPENSER	MPD
TYPE OF VAPOR SYSTEM	VACCUM ASSIT.

TESTING UNIT	TRI TESTER #435697
SERIAL #	0435679
CALIB. DATE	3/4/2010
NEXT CALIB. DATE	3/4/2011

PUMP #	GAS GRADE	NOZZLE MODEL & SERIAL	GASOLINE PUMPED GALLONS	ALLOWABLE FLOW RATE PER MINUTE	FLOW RATE PER MINUTE	FLOWRATE PASS/FAIL	ALLOWABLE A/L RATE RANGE	A/L RATE	A/L RATE PASS/FAIL	PASS/FAIL
3	MID	RICHARDS ASTRO VAC	3	6 - 10	6.82	PASS	0.9 - 1.1	1.07	PASS	PASS
3	PRE	RICHARDS ASTRO VAC	3	6 - 10	6.93	PASS	0.9 - 1.1	1.06	PASS	PASS
3	REG	RICHARDS ASTRO VAC	3	6 - 10	6.7	PASS	0.9 - 1.1	1.04	PASS	PASS
4	MID	RICHARDS ASTRO VAC	3	6 - 10	6.82	PASS	0.9 - 1.1	1.03	PASS	PASS
4	PRE	RICHARDS ASTRO VAC	3	6 - 10	6.93	PASS	0.9 - 1.1	1.02	PASS	PASS
4	REG	RICHARDS ASTRO VAC	3	6 - 10	6.76	PASS	0.9 - 1.1	0.91	PASS	PASS

TESTERS NAME	SIGNATURE	DATE