

CITY OF TOLEDO



DEPARTMENT OF PUBLIC UTILITIES

May 20, 2008

Mr. Steven M. Smith
Director
FirstEnergy Generation Corp.
Bay Shore Plant
76 South Main Street
Akron, Ohio 44308

Re: COMS Warning Letter (HPV-GC7)

Dear Mr. Smith:

I am writing with regards to the 1st quarter 2008 report submitted by the Bay Shore Plant for the carbon monoxide continuous emissions monitoring system (CO CEMS) serving the Circulating Fluidized Bed Boiler (OEPA Emissions Unit 0448020006 B006). It was reported that the monitoring system downtime was greater than 5% of the operating time during the quarter.

Please be aware that future CO CEMS downtime at this unit may result in a Notice of Violation.

If you have any questions, please feel free to contact me at 419-936-3938.

From Toledo - an International Award Winning City!

A handwritten signature in black ink that reads "Matthew A. Stanfield".

Matthew A. Stanfield
Staff Professional Engineer

cc: Karen Granata
Todd Brown, OEPA
Lisa Holscher, USEPA