

CITY OF TOLEDO

HPV-6C7



DEPARTMENT OF PUBLIC UTILITIES

April 7, 2008

Mr. Steven M. Smith
Director
FirstEnergy Generation Corp.
Bay Shore Plant
76 South Main Street
Akron, Ohio 44308

Re: COMS Warning Letter

Dear Mr. Smith:

I am writing with regards to the 4th quarter 2007 report submitted by the Bay Shore Plant for the continuous opacity monitoring system (COMS) serving the Circulating Fluidized Bed Boiler (OEPA Emissions Unit 0448020006 B006). It was reported that the monitoring system downtime was greater than 7% of the operating time during the quarter.

Please be aware that future COMS downtime at this unit may result in a Notice of Violation.

If you have any questions, please feel free to contact me at 419-936-3938.

Sincerely,

A handwritten signature in black ink that reads "Matthew A. Stanfield".

Matthew A. Stanfield
Staff Professional Engineer

cc: Karen Granata
Todd Brown, OEPA
Lisa Holscher, USEPA

Timothy D. Murphy, Commissioner
DIVISION OF ENVIRONMENTAL SERVICES
Quilter Environmental Center
348 South Erie Street, Toledo, Ohio 43604-8633 USA
Telephone: 419-936-3015 Fax: 419-936-3959 E-mail: tim.murphy@toledo.oh.gov