

CITY OF TOLEDO



DEPARTMENT OF PUBLIC UTILITIES

February 7, 2007

Mr. Ron Hudson
Complex Environmental Manager
Johns Manville - Plant #1
6050 River Road
Waterville, Ohio 43566

Certified Warning Letter

RE: Title V Quarterly Report - 4th Quarter 2006

Dear Mr. Hudson:

Pursuant to Part III.A.II.3 of the Title V permit for Johns Manville, Plant #1, the pressure drop across the baghouse for the Wet Process Fiberglass Mat Oven (P015) shall be maintained within a range of two to six inches of water while the emission unit is in operation. Upon evaluation of the 4th quarter 2006 Title V report, the pressure drop across the baghouse operated outside the two to six inch water column for 24 hours on December 14, 2006 and for 332 hours between December 15, 2006 and December 29, 2006.

This letter serves as a warning that similar occurrences in the future may result in a Notice of Violation.

Please feel free to contact me at (419) 936-3963 if you have any questions regarding this letter.

Yours from Toledo - an All-America City!

Brad Faggionato, Engineer - Air Resources

cc: T. Casey Stephens, Commissioner of Environmental Services
Karen Granata, P.E., Chief of Air Resources
Leslie Kovacik, Law Department
John Paulian, OEPA
Lisa Holscher, USEPA Region V

T. Casey Stephens, Commissioner
DIVISION OF ENVIRONMENTAL SERVICES
Quilter Environmental Center
348 South Erie Street, Toledo, Ohio 43604-8633 USA
Telephone: 419-936-3015 Fax: 419-936-3959 E-mail: casey.stephens@toledo.oh.gov