

File Sun Corres.
copy

CITY OF TOLEDO



DEPARTMENT OF PUBLIC

February 1, 2007

CERTIFIED MAIL

Mr. Michael Bukowski
Sunoco, Inc. (R&M)
P.O. Box 920
Toledo, Ohio 43697-0920

Re: Excess Emissions from the SRU CEM (P012)

Dear Mr. Bukowski:

I am writing in regards to the fourth quarter, 2006, SRU sulfur dioxide CEM report submitted by the Sunoco, Inc., Toledo refinery, dated January 26, 2007. The continuous emissions monitoring system (CEMS) for sulfur dioxide for emissions unit P012 reported operating time with excess emissions greater than 5% during the reported quarter. It was documented as a malfunction due to an unexpected loss of power to the refinery on Dec. 15, 2006 and resulted in continuous problems to the fluid catalytic cracking unit and the sulfur recovery unit until December 24, 2006.

Please be aware that future excess emissions from the sulfur dioxide CEMS may result in a Warning Letter or Notice of Violation.

If you have any questions, please feel free to contact me at 419-936-3955.

Yours from Toledo - An All-America City!

Pamela Barnhart
Environmental Engineer

cc: Karen Granata
Todd Brown, OEPA
John Paulian, OEPA

2980 2222 1000 0922 8002

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only. No insurance coverage provided)
For delivery information visit our website at www.usps.com

OFFICIAL USE

Postage	\$	Postmark Here PB
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To: Mr. Michael Bukowski
Street, Apt. No., or PO Box No. P.O. Box 920
City, State, ZIP+4 Toledo, OH 43697-0920

T. Casey Stephens, Commissioner
DIVISION OF ENVIRONMENTAL SERVICES
Quilter Environmental Center

348 South Erie Street, Toledo, Ohio 43604-8633 USA
Telephone: 419-936-3015 Fax: 419-936-3959 E-mail: casey.stephens@toledo.oh.gov