



City of Cleveland
Frank G. Jackson, Mayor

Department of Public Health
Division of Air Quality
75 Erieview Plaza, Second Floor
Cleveland, Ohio 44114-1839
216/664-2297 • Fax: 216/420-8047
www.clevelandhealth.org

**SERVING OHIO EPA AS AGENCY 13
FOR CUYAHOGA COUNTY**

**CERTIFIED MAIL 7011 2000 0002 6936 3136
RETURN RECEIPT REQUESTED**

August 15, 2012

Darwin McClellan
Fleet Data Manager
City of Cleveland
Division of Motor Vehicle Maintenance
4150 East 49th St.
Cleveland, OH 44105

FACILITY ID: 13-18-36-8023

**RESOLUTION OF VIOLATIONS
NOTICE OF VIOLATION FOLLOW-UP LETTER**

Dear Mr. McClellan:

On July 27, 2012, the Cleveland Division of Air Quality (CDAQ) inspected the City of Cleveland Division of Motor Vehicle Maintenance Harvard Yards gasoline dispensing facility (City of Cleveland Division of Motor Vehicle Maintenance) located at 4410 Harvard Avenue in Newburgh Heights. The City of Cleveland Division of Motor Vehicle Maintenance failed an Air-to-Liquid (A/L) ratio test on Terminal #51, pump #2 on July 27, 2012, for emissions unit (EU) G001: Gasoline dispensing facility with Stage I and Stage II controls. CDAQ then issued a Notice of Violation on August 3, 2012, requesting that the City of Cleveland Division of Motor Vehicle Maintenance make the necessary repairs to Terminal #51, pump #2, conduct a re-test of the Air-to-Liquid Ratio test and then submit test results within thirty (30) days of receipt of the letter.

CDAQ is in receipt of passing Stage II test results for Terminal #51, pump #2, dated August 13, 2012.

The corrective action plan was received in a timely manner and appropriate steps were taken to bring the source into compliance. CDAQ has determined that no further enforcement action is warranted at this time, but reserves its right to take such action in the future if necessary.

CDAQ issues this letter with Ohio EPA's concurrence and does not excuse any violations of local, state and federal laws or regulations regarding air pollution control. Violations of air pollution control laws may be pursued in local court or referred to Ohio EPA or U.S. EPA for further enforcement action.



Should you have any questions, please call Megan Murphy at 216-664-4258. All correspondence with CDAQ must include the Ohio EPA facility identification number for City of Cleveland Division of Motor Vehicle Maintenance: 13-18-36-8023.

Sincerely,

A handwritten signature in black ink that reads "Valencia White".

Valencia White
Chief of Enforcement, CDAQ

VW/mm LW

cc: John Paulian, Ohio EPA Central Office
William MacDowell, U.S. EPA Region V
L:\Data\Facilities\1318368023\2012-7-27 ROV + NEAR.doc