

AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

January 17, 2007

1677 010859  
Mr. Amin Mohammad  
United Petroleum Marketing LLC  
9391 Chesapeake Drive  
North Royalton, OH 44133

Dear Mr. Mohammad:

On January 11, 2007, a representative of the Akron Regional Air Quality Management District inspected the United Petroleum Marketing #101 gasoline dispensing facility located at 389 E. Waterloo Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: Incomplete record keeping was available for review. United Petroleum Marketing is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review. A certificate of Stage II training must be on file at this location.

ARAQMD: A review of our records found this facility has not submitted the results of Stage II testing for 2003 & 2006. Failure to complete Stage II vapor recovery testing is a violation of OAC rule 3745-21-09 (DDD)(2)(c)(d) and the California Air Resources Board (CARB) executive order G-70-150 issued for the Gilbarco vapor recovery system installed at this location.

Within 15 days of receipt of this letter, United Petroleum Marketing LLC is to submit in writing what has been done to correct the violations cited in this letter.

Acceptance of correction of deficiencies does not constitute a waiver of the Ohio EPA's or its authority to seek civil penalties as provided in Section 3704.99 of the Ohio Revised Code. The determination to pursue or decline such penalties in this case will be made at a later date.


CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964

Mr. Amin Mohammad  
Page 2  
January 17, 2007

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact Susan Anderson at 330/375-2480 x6053.

Sincerely,



Steven Stakoff, RS  
Sanitarian II

SS  
Certified Mail