



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

December 1, 2008

1677610794
Mr. Suleiman Alahmad
c/o Adam Fadwa LLC
6900 Harvard Avenue, Suite 203
Cleveland, OH 44105

Dear Mr. Alahmad:

On November 17, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Sunoco gasoline dispensing facility located at 1432 Massillon Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: No record keeping was available for review. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which requires Stage II record keeping to be available for review.** You must establish a Station file with the required information and obtain a certificate of Stage II training.

Equipment: The cap for the regular product vapor drybreak is broken and needs immediate replacement. The hoses on dispensers #2 & #5 are crimped at the nozzle end and are in need of replacement.

ARAQMD file: A review of our records found that this facility is late for Stage II testing which was due on or before 11/30/08, and the Ohio EPA Permit to Operate will expire on 12/9/08. **This facility is in violation of OAC rule 3745-21-09 (DDD)(2) which specifies the testing required and its frequency.**

The forms necessary to renew this permit are enclosed. **Schedule testing and submit the application immediately.**

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA
Enclosures
Certified Mail
cc Rami Jaber at Station address

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper