



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

July 14, 2008

1667 646130
Mr. Brian Keller
Suffield Carry Out
1435 State Route 43
Suffield, OH 44260

Dear Mr. Keller:

On July 1, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Suffield Carry Out gasoline dispensing facility located at 1435 State Route 43 in Mogadore to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: The results of Stage II testing for testing completed in 2007 were not in the Station file. A current certificate of Stage II Vapor Recovery Training & Ohio EPA Permit to Operate must be obtained and placed in the Station file. **Suffield Carry Out is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies the records that are to be kept.**

ARAQMD file: Also, the Ohio EPA Permit to Operate for this facility expired today (7/14/08). **Ohio Administrative Code 3745-35-02 requires issuance of a Permit to Operate (PTO) before any air contaminant source can be operated. Ohio Revised Code section 3704.05 prohibits any violation of the Ohio Environmental Protection Agency (Ohio EPA) regulations, and provides for civil and criminal penalties for violations.** To date, this Agency has not received a renewal application.

Within 15 days of receipt of this letter, you are required to correct the deficiencies cited. Copies of the forms you need to complete are enclosed. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA
Certified Mail
Enclosures

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper