



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

March 7, 2008

1677 000127  
Mr. Sukhdev Singh  
BJ Boss Marathon  
1904 Copley Road  
Akron, OH 44320

Dear Mr. Singh:

On February 26, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the BJ Boss Marathon gasoline dispensing facility located at 1904 Copley Road in Copley to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

ARAQMD file: A review of our records found this facility failed to complete Stage II testing in 2007. **BJ Boss Marathon is in violation of the California Air Resources Board (CARB) certification, G-70-150, for the Gilbarco vapor recovery system installed at this location.** This certification requires annual testing be done and not to exceed 12 months of the previous year's testing. Further testing violations will not be tolerated.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964