



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency \* Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

March 7, 2008

Mr. Basem I. Ali  
Giant Ohio LLC  
3904 Corporex Park Drive #150  
Tampa, FL 33619

Dear Mr. Ali:

On March 4, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Giant Ohio BP #441 gasoline dispensing facility located at 2836 E. Waterloo Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: There was no record keeping available for review. Giant Oil LLC is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies record keeping and its availability. A certificate of Stage II training must be obtained and a copy placed in the Station file.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964