



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

January 30, 2008

1677010915
Mr. Rahif Faris
Waterloo Marathon
598 E. Waterloo Road
Akron, OH 44319

Dear Mr. Faris:

On January 23, 2008, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Waterloo Marathon gasoline dispensing facility located at 598 E. Waterloo Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

- Record keeping: There was no record keeping available for review. **Waterloo Marathon is in violation of OAC rule 3745-21-09 (DDD)(3)** which requires Stage II record keeping to be available for review. **You must establish a Station file with the required information and obtain a certificate of Stage II training.**
- Equipment: This facility failed Stage II testing on 1/23/08. Timely repair and retesting are required.
- ARAQMD file: A review of our files found this facility failed to complete testing in 2007. **Waterloo Marathon is in violation of OAC rule 3745-21-09 (DDD)(2). This facility must successfully test the vapor recovery system annually.** In a January 4, 2008 letter from this Agency, you were given a form to complete to transfer the Ohio EPA Permit to Operate. Please submit this form. You may fax (330/375- 2480) or mail your submittal.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper