

AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

June 18, 2007

Mr. David Dodson  
Sheetz, Inc.  
5700 Sixth Avenue  
Altoona, PA 16602

Dear Mr. Dodson:

Our Agency is in receipt of the December 28, 2006, Stage II test results submitted by Mass Tech USA (now Leighton O'Brien Inc.) for the Sheetz #393 gasoline dispensing facility located at 2495 East Aurora Road in Twinsburg.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, Sheetz, Inc. is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days following the completion of the tests.** The test results for this location were received June 11, 2007.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)(b)(c)(d). This facility will be due for full testing on or before 12/28/11. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053

Sincerely,



Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964

1677130082