

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

May 17, 2007

Mr. Dan Gross
Sam's Club
608 SW 8th Street
Bentonville, AR 72712

Dear Mr. Gross:

Our Agency is in receipt of the March 14, 2007, Stage II test results submitted for Sam's #4750 gasoline dispensing facility located at 1189 Buchholzer Boulevard in Cuyahoga Falls.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, Sam's Club is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days following the completion of the tests.** The test results for this location were received on May 16, 2007.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). The above facility will be due for full testing on or before 3/14/12. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

1677 050179