



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

January 11, 2007

Mr. Iqbal Boparai
Oakhill Food Mart
2514 Mogadore Road
Akron, OH 44312

Dear Mr. Boparai:

1677010839
Our Agency is in receipt of the January 4, 2007, Stage II test results submitted for the Sunrise Petroleum's Oakhill Food Mart gasoline dispensing facility located at 2514 Mogadore Road in Akron.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, Sunrise Petroleum is in violation of CARB certification G-70-153 AD for the Wayne vapor recovery system installed at this location for failure to annually test in 2006.**

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)(b)(c)(d). This facility will be due for **full testing** on or before 1/4/12. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L test as specified within the CARB Executive Orders and/or by this Agency **must be performed annually**, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 ext 6053.

Sincerely,

Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964