



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

January 4, 2008

1677 6610915  
Mr. Nader Awad  
Waterloo Marathon  
598 E. Waterloo Road  
Akron, OH 44319

Dear Mr. Awad:

On December 12, 2007, a representative of the Akron Regional Air Quality Management District inspected the Waterloo Marathon gasoline dispensing facility located at 598 E. Waterloo Road in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

- Record keeping: There was no record keeping available for review. **Waterloo Marathon is in violation of 3745-21-09 (DDD)(3)** which requires Stage II record keeping to be available for review. You must establish a Station file with the required information and obtain a certificate of Stage II training.
- Equipment: The dispensers at this location have been replaced and must be tested according to OAC rule 3745-21-09 (DDD)(2)(a) the Stage II vapor recovery system must be tested. Schedule testing immediately.
- ARAQMD file: Information regarding the Ohio EPA Permit to Operate for this facility is enclosed with a separate letter of explanation. Please submit transfer information immediately. Also, this Agency has not received the results of Stage II testing for 2007. Submit results immediately.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964