

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

December 14, 2007

Mr. Sukhdev Singh
1371 High Street, #104
Wadsworth, OH 44281

Dear Mr. Singh:

On December 10, 2007, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the BJ Boss Marathon gasoline dispensing facility located at 1904 Copley Road in Copley to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Equipment: Dispenser #2 was out of order, and the hose on dispenser #3 needs to be replaced.

ARAQMD file: A review of our records found this facility has not submitted the results of Stage II testing for 2007. This facility was due for testing on or before 9/5/07. **BJ Boss Marathon is in violation of the California Air Resources Board (CARB) certification, G-70-150, for the Gilbarco vapor recovery system installed at this location.** This certification requires annual testing not to exceed 12 months of the previous year's testing. **TEST the system right away.**

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964

1677 000127