



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

December 14, 2007

1677 010941
Mrs. Manjit Kaur
Akron Food Mart
737 Kenmore Boulevard
Akron, OH 44314

Dear Mrs. Kaur:

On December 11, 2007, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the Akron Food Mart gasoline dispensing facility located at 737 Kenmore Boulevard in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

Record keeping: Stage II test results completed in 2004, 2005, & 2006 and a certificate of Stage II Vapor Recovery Training were missing from the Station file. **OAC 3745-21-09 (DDD)(3)(vi) requires proof of attendance and completion of training required by the Ohio EPA for the operator or local manager of the gasoline dispensing facility.**

ARAQMD file: A review of our records found that Stage II testing is due on or before 12/22/07. If you have not done so, schedule testing immediately.

Enclosed is a list companies that test Stage II systems and also provide Stage II training. Obtain certification immediately.

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA
Enclosure

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964