



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

November 16, 2007

Mr. James Olson
Jim's Fuel & Deli
9790 E. Center Street
Windham, OH 44288

Dear Mr. Olson:

On November 15, 2007, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected Jim's Fuel & Deli gasoline dispensing facility located at 9790 E. Center Street in Windham to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

Inspection results/Deficiencies:

- Record keeping: The results of Stage II testing completed 1/16/06 were not in the Station file.
- Equipment: The coaxial fill for the regular unleaded product is not sealing and is in need of repair.
- ARAQMD file: **A review of our records found Jim's Fuel & Deli to be in violation of OAC rule 3745-21-09(DDD)(2) which specifies testing requirements. This facility was due for Stage II testing on or before 1/16/07. Schedule testing immediately.**

Please correct the deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,

Steven Stakleff, RS
Sanitarian II

SS

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper