



**AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT**

*Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties*

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

August 24, 2007

1677010909

Mr. Usman Ghandi  
Clark Mart  
4368 Sleepy Hollow Cove  
Lilburn, GA 30047

Dear Mr. Ghandi:

On August 18, 2007, a representative of the Akron Regional Air Quality Management District inspected the Clark Mart gasoline dispensing facility located at 2115 East Avenue in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.


**Inspection results/Deficiencies:**

Record keeping: The results of Stage II testing completed in 2006, a certificate of Stage II vapor recovery training, and a copy of the Ohio EPA Permit to Operate for this facility were not in the Station file. **Clark Mart is in violation of OAC rule 3745-21-09 (DDD)(3)(a) which specifies what records are to be maintained.** Obtain a certificate of Stage II training right away.

Within 14 days of receipt of this letter you are to submit to Agency, in writing, what has been done to correct these record keeping violations.

Please correct any deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,  
  
Steven Stakleff, P.E.  
Sanitarian II

SS  
Certified Mail

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
*An equal opportunity employer and provider of services - CRA 1964*