



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

September 16, 2008

Ms. Denise Lees  
BP Products North America Inc.  
Environmental Department  
PO Box 6038  
Artesia, CA 90702

Dear Ms. Lees:

Our Agency is in receipt of the May 30, 2008, Stage II test results submitted by Tanknology for the BP #22501 gasoline dispensing facility located at 9202 State Route 14 in Streetsboro.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, BP Products North America Inc. is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that the results of Stage II testing be submitted to the Ohio EPA or its delegated local air agency within thirty days following the completion of the tests.** The test results for this location were received September 10, 2008.

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). This facility will be due for **full testing** on or before **5/30/13**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L test as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964



Printed on Recycled Paper

1667080019