

AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

March 18, 2008

1677610915
Mr. Raheef Faris
Waterloo Oil Company
598 E. Waterloo Road
Akron, OH 44319

Dear Mr. Faris:

Our Agency is in receipt of the March 4, 2008, Stage II test results submitted by ECT for the Waterloo Marathon located at 598 W. Waterloo Road in Akron.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility.


Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)(b)(c)(d). This facility will be due for **full testing** on or before 3/4/13. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L testing as specified within the CARB Executive Orders and/or this Agency must be performed **annually**, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

This facility also did not complete testing in 2007 and is in violation of the CARB **certification** for the vapor recovery system installed in this location. Future testing violations will cause this Agency to seek enforcement action.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,



Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964