



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

October 6, 2008

1667030020  
Mr. Tom Mikulski  
Sky Plaza, IGA  
8283 Windham St.  
Garrettsville, Ohio 44231

Dear Mr. Mikulski:

Per our phone conversation on October 6, 2008, I have confirmed that the gasoline dispensing facility located at 8283 Windham St. in Garrettsville has been sold to you.

This facility has Stage II vapor recovery control and is subject to **annual testing, inspections, training certification and record keeping requirements per OAC rule 3745-21-09 (DDD)**. I have faxed you information regarding the EPA requirements for operation of gasoline dispensing facilities including a list of testing companies.

Stage II rule requires testing to be completed annually, not to exceed 12 months of the previous years testing. This facility last completed Stage II testing on June 14, 2007 and is overdue for testing for this year. **Please schedule testing immediately.**

A review of our records confirmed that the Ohio EPA Permit by Rule (PBR) for this facility is in the name of Porter's IGA and held by Mike Porter. Enclosed with this letter is the form necessary to apply for the Ohio EPA PBR. **Ohio Administrative Code 3745-35-02, requires issuance of a Permit to Operate or PBR before any air contaminant source can be operated. Ohio Revised Code section 3704.05 prohibits any violation of the Ohio Environmental Protection Agency (Ohio EPA) regulations, and provides for civil and criminal penalties for violations.**

If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

*An equal opportunity employer and provider of services - CRA 1964*



Printed on Recycled Paper