



AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

April 1, 2008

1677050139  
Ms. Cecy Kinne  
Speedway SuperAmerica, LLC  
PO Box 1500  
Springfield, OH 45501

Dear Ms. Kinne:

On December 13, 2007, this Agency received a complaint regarding excessive emissions occurring during fuel deliveries at your gasoline dispensing facility #9178 located at 2026 Bailey Road in Cuyahoga Falls.

On December 17, 2007, I spoke with you about witnessing a fuel delivery at this location. It was arranged for me to witness a delivery on January 7, 2008. At that time it was determined that excessive vent emissions do occur during delivery of fuel to the underground storage tank. George, of your maintenance department, was to replace vent caps and we were to again witness another fuel drop to see if that solved the situation. On January 25, 2008, a fuel drop was witnessed. The problem of excessive emissions had not been corrected. George said that he would have Empaco look at the site for a possible solution.

On March 24, 2008, I spoke with George. He said Empaco had not gotten back to him yet. He is to let me know what was determined.

This letter is to inform you that the situation is in need of prompt correction. Within 14 days of receipt of this letter, Speedway SuperAmerica LLC is to submit a plan for the correction of this nuisance condition in writing to this Agency.

If you have any questions, please contact me at 330/375-2480 x6053.

Sincerely,

Susan Anderson  
Sanitarian II

SA  
Certified Mail

CITICENTER - SUITE 904  
146 SOUTH HIGH STREET • AKRON, OHIO 44308  
An equal opportunity employer and provider of services - CRA 1964