



AKRON REGIONAL
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480
FAX: (330) 375-2402

L. M. Malcolm, P.E.
Administrator

January 21, 2009

1677010297
Mr. Robert E. Williams II
First Energy/Ohio Edison
76 S. Main Street
Akron, OH 44308

Dear Mr. Williams:

Our Agency is in receipt of the August 26, 2008, Stage II test results submitted for the First Energy gasoline dispensing facility located at 1910 W. Market Street in Akron, Ohio.

Upon review, the test results are accepted as received and will be included in the Operating File for this facility. **However, First Energy is in violation of OAC rule 3745-21-09 (DDD)(2)(c) which requires that results of Stage II testing be submitted within 30 days of the test's completion.**

Full compliance testing, as conducted at this facility, must be performed again within five year intervals according to the testing requirements of OAC rule 3745-21-09 (DDD)(2)(a)&(b). The above facility will be due for **full testing** on or before **08/26/13**. Notification of testing is required as before, as well as reporting requirements.

I would also like to remind you that the Static Leak Test and A/L test as specified within the CARB Executive Orders and/or by this Agency must be performed annually, not to exceed one year from the last test performed. You are required to notify us before testing, and the results of the annual performance test are to be submitted within thirty (30) days of the test's completion.

If you have any questions, please contact me at (330) 375-2480 x6053.

Sincerely,

Susan Anderson
Sanitarian II

SA

CITICENTER - SUITE 904
146 SOUTH HIGH STREET • AKRON, OHIO 44308
An equal opportunity employer and provider of services - CRA 1964