



# AKRON REGIONAL AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

July 9, 2008

Mr. Joseph Moneskey  
Gas & Oil, Inc.  
1276 Krumroy Road  
Akron, OH 44306

Dear Mr. Moneskey:

A representative of the Akron Regional Air Quality Management District (ARAQMD) inspected the following Gas & Oil gasoline dispensing facilities to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery:

<u>Date</u>	<u>Site</u>	<u>Address</u>	<u>City</u>
7/7/08	2	1475 Massillon Road	Akron 1677010944
7/7/08	3	745 E. Archwood Avenue	Akron 1677011130
7/7/08	7	1980 S. Arlington Road	Akron 1677000534
? — 7/7/08	15	3849 S. Main Street	Akron 1677000571
7/7/08	19	455 W. Turkeyfoot Lake Road	Akron 1677011087

## Inspection results/Deficiencies:

### Site    Deficiency

2      This facility was found closed at time of inspection. The Ohio EPA Permit to Operate for this facility expired on 9/11/07. **Renewal of the permit and compliance with the Stage II rule must be completed before operation.**

3      Record keeping:      No records were available for review. A certificate of Stage II training must be obtained and a copy kept in the Station file. **Gas & Oil, Inc. is in violation of OAC rule 3745-21-09 (DDD)(3) which specifies the records that are to be kept.**

Equipment:              The nozzle on dispenser #4 is not CARB certified for the Gilbarco vapor recovery system. Replace nozzle immediately with a certified nozzle. The Stage I product adaptors and Stage I fill adaptors are not CARB approved which prevent loosening or over tightening.

CITICENTER - SUITE 904

146 SOUTH HIGH STREET • AKRON, OHIO 44308

*An equal opportunity employer and provider of services - CRA 1964*