

AKRON REGIONAL  
AIR QUALITY MANAGEMENT DISTRICT

Agent of the Ohio Environmental Protection Agency • Division of the Akron Health Department  
Serving Medina, Portage and Summit Counties

TELEPHONE: (330) 375-2480  
FAX: (330) 375-2402

L. M. Malcolm, P.E.  
Administrator

June 1, 2011

1677010824  
Mr. Harshinder Kaur  
Fuel America  
4737 Lixington Ridge Drive  
Akron, OH 44313

Dear Mr. Kaur:

On January 26, 2011, a representative of the Akron Regional Air Quality Management District (ARAQMD) inspected Fuel America gasoline dispensing facility at 813 Lovers Lane in Akron to determine compliance with OAC 3745-21-09 (DDD) regarding Stage II vapor recovery.

**Inspection results/Deficiencies:**

Record keeping: No record keeping was available for review. **This facility is in violation of OAC rule 3745-21009 (DDD)(3) which specifies Stage II record keeping to be available for review.** You must establish a station file with the required information and obtain a certificate of Stage II training.

ARAQMD file: This facility is eligible for a different kind of permitting called Permit by Rule. Enclosed with this application is the forms necessary to apply and directions. Submit this application to this Agency if you wish to change how you are permitted.

Correct deficiencies noted. This facility will be inspected on an annual basis for compliance with the Stage II vapor recovery rule. It is required that you keep record keeping information at a readily available location for inspection. For this Agency, it is requested that you keep copies of the required information at each individual location where all employees can access them.

Thank you for your cooperation and assistance in this matter. If you have any questions, please contact me at 330/375-2480 x4255.

Sincerely,



Steven Stakleff, RS  
Sanitarian II